



## ENGINEERING DIVISION FIELD REPORT

Project	Report
SubProjectLog # : 2019-AM-0415-CN.1	Date: 9/9/2019
Name: Blu Restaurant	Type: Investigation
Type: Sewer Connection (CN)	Observer: Alderislo, Dave
Address: 825 South Lake Blvd	Time: 10:00 AM
Town: Town of Carmel	Weather: Sunny
County: Putnam	Temperature: 70
Basin: Amawalk	
Tax Map #: 75.43-1-22	

Telephone:

Interviewee: Michael Barile, Jack Karell, P.E.

### Project History

### Findings

9/4/2019 -DEP performed a site inspection with property owner Michael Barile and engineer Jack Karell. Reason for the site inspection was to perform a dye test on existing SSTS only and not existing force main. Both the property owner and engineer stated the force main for the restaurant (installed 1993) was on-line/operational at the time of the site inspection. Mr. Barile stated the cap on the force main in the manhole at the intersection of 6N and Clark Place, was removed the previous week. The existing SSTS was not dye tested at this time.

In addition, kitchen wastewater was observed on the ground at the back door of the kitchen migrating onto adjacent property. Photos taken. PCDOH was notified.